Grand County Building Department
Daily Inspection Record

DATE OF INSPECTION: **APRIL 23, 2010**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS/FAIL	COMMENTS
AMATO	B09-0453	FRAME	PASS	
STEWART	B08-0182K	DRYWALL	PASS	
PHILBECK	B09-0402	HVAC	FAIL	Need weather cap and 1" spacing around pipe
GAIER	B10-0068	INSULATION	PASS	
PATTON	B09-0337	HVAC	PASS	
PATTON	B09-0337	FINAL	FAIL	Need appliances
PATTON	B09-0529	FINAL	PASS	
LEBLOND	B100036GL	FRAME	PASS	GREAT ROOM ONLY
ALLAND	B09-0490	ICE AND WATER	FAIL	SNOW ON ROOF
THOMASSON	B08-0325	ROOF COVERING		Cancel by owner

PURGE INSPECTIONS

LAST NAME	PERMIT NUMBER	STATUS OF PROJECT	TYPE OF PROJECT	COMMENTS