Grand County Building Department
Daily Inspection Record

DATE OF INSPECTION: **DECEMBER 17, 2010**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
LACEY FAMILY LLP	B05-0520G	FINAL	FAIL	REMOVE DAMPER FROM FIREPLACE
LAU	B10-0315	FRAME	PASS	
LAU	B10-0315	PLUMBING	PASS	
LAU	B10-0315	GAS	PASS	
CLIMAX	B10-0302	FRAME	PASS	
LEUNBERGER	B10-0460	FINAL	PASS	
LONG	B10-0274	DRYWALL	PASS	
WACKER	B10-0146	INSULATION	PASS	
STILL	B10-0397	FINAL	PASS	
CARPENTER	B10-0267	INSULATION, FRAME	PASS	
CARPENTER	B10-0267	HEAT AND VENT	PASS	
COLORADO RIVER CATTLE RANCH	B10-0462	HEAT AND VENT	PASS	
CW REVIVAL ENTERPRISE, LLC	B10-0271	FINAL	PASS	
KNIGHT/REEMAN	B08-0485	INSULATION	FAIL	DOES NOT MEET REQUIRED THICKNESS