

**Grand County Building Department
Daily Inspection RESULTS**

DATE OF INSPECTION: November 27, 2013

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
ZAPFEL	B13-0288	ICE & WATER	PASS	
EDWARDS	B13-0354GL	ICE & WATER	PASS	
EDWARDS	B13-0354GL	GAS PIPING	PASS	
EDWARDS	B13-0354GL	ROUGH PLUMBING	PASS	
NAUMANN	B13-0490	PIERS	PASS	
QUAD RANCH, LLC	B13-0242	DRYWALL	PASS	
MCGINNES	B13-0314	FINAL	PASS	
RUUHELA	B12-0476	ROOF COVER	PASS	
RUUHELA	B12-0476	HVAC	PASS	
RUUHELA	B12-0476	FINAL	PASS	
BLAIR	B13-0241	HVAC	FAIL	FIRE STOPS AT TRUSSES
BLAIR	B13-0241	ROUGH PLUMBING	PASS	
BLAIR	B13-0241	FRAME	FAIL	TRUSS BRACING, TRUSS CLIPS
VANIMAN	B13-0268	GAS PIPING	PASS	
VANIMAN	B13-0268	ROUGH PLUMBING	PASS	
VANIMAN	B13-0268	FRAME	PASS	
REALL	B13-0478GL	FOOTER	PASS	
GYULA	B13-0467	INSULATION	PASS	
RODARMEL	B13-0468	INSULATION	PASS	
SENOVAITIENE	B06-0739	FINAL	FAIL	WATER HEATER, GAS FIREPLACES, HANDRAILS
YMCA	B13-0159	ICE & WATER	PASS	
FRASER VALLEY METRO REC.DIST.	B13-0488	GAS PIPING	PASS	