Grand County Building Department
Daily Inspection Record

DATE OF INSPECTION: **MAY 11, 2010**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS/FAIL	COMMENTS
RITCHARD	B05-0284	FRAME	FAIL	NEED TRUSS ENGINEERING CALL FOR REINSPECTION
RITCHARD	B05-0284	PLUMBING	PASS	
RITCHARD	B05-0284	GAS	PASS	
AMATO	B09-0453	INSULATION	PASS	
HANSON	B09-0222	DRYWALL	PASS	
LEHMAN	B09-0083	DRYWALL	PASS	

PURGE INSPECTIONS

LAST NAME	PERMIT NUMBER	TYPE OF PROJECT	COMMENTS
PEAK RANCH INC	B00-0304	DECKS, PORCH, ROOF	CLOSE BY PRUGE