Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **APRIL 17, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
GILLIS	B13-0172	FINAL	PASS	
OURAY RANCH	B14-0042	DECK WALL STUD	PASS	
ARNOLD/LANGENDOEN	B13-0358GL	DRYWALL	PASS	*DRIVE WAY UNDER GARAGE NEEDS 5/8 DRYWALL HUNG IN IT*
SACHTLEBEN	B14-0046	ROUGH PLUMBING	PASS	
CONGER	B14-0038	ICE AND WATER SHEILD	PASS	*GARAGE ONLY*