Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **MAY 2, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
BUSSE	B13-0226	DRYWALL	PASS	
BUSSE	B13-0226	DECK FRAME	PASS	
WILLIAMS/917 PARTNERS	B13-0510GL	FRAME	PASS	
MULLINEX	B14-0052	FOUNDATION	PASS	
MULLINEX	B14-0052	PIERS	PASS	
C LAZY U/WILLOW CABIN	B14-0016	FINAL	FAIL	*NEED GUARD RAIL AND HAND RAIL STAIRS ON BOTH END OF STEPS*
SMITH	B14-0060	GAS PIPING	PASS	
GRANBY JONES	B14-0066	XCEL PRESSURE TEST	FAIL	*NO PRESSURE*
SCHAFFER	B13-0414	FINAL	PASS	
SCHAEFER	B13-0414	ROOF COVERING	PASS	
CONGER	B14-0038	INSULATION	PASS	*OVERLAY*