Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JULY 2, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
HOWES	B13-0287	FOOTING	PASS	
COOPER	B14-0192	FRAMING	FAIL	*1)BEAM NEEDS 2 BOLTS ON EACH SIDE OF SPLICES. 2)BOTTOM RAIL ON SIDES NEEDS TO HAVE WIRE SECURED TO IT*
COOPER	B14-0192	FINAL	FAIL	*FOR FINAL, CURE 1 AND 2 OF FAMEING AND PUT SNOW STOP ON*
TOWN OF GRAND LAKE	B14-0137GL	FINAL	PASS	
DART	B14-0161	FOUNDATION	PASS	
MOONY	B10-0127	FRAME	FAIL	*NEED HURRICANE CLIPS*
MOONY	B10-0127	ROOF COVERING	PASS	
MOONY	B14-0089	ROOF COVERING	PASS	
MOONY	B14-0089	FINAL	PASS	