Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **August 27, 2013**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
SOMMERFELD	B13-0107	FOUNDATION	PASS	
OLSEN	B13-0193	FINAL	PASS	
VOGEL	B08-0295	FINAL	FAIL	*SEE NOTE ON JOB SITE*
KUNC	B13-0252GL	FRAME	PSSS	
SPADE	B12-0589K	FRAME	PASS	
SPADE	B12-0589K	ROOF	FAIL	*NEED SNOW STOPS*
SPADE	B12-0589K	FINAL	FAIL	*EXTERIOR NEEDS TO BE 100% COMPLETE*
BORGEN	B13-0093GL	FRAME	PASS	
BORGEN	B13-0093GL	HVAC	FAIL	
BORGEN	B13-0093GL	ROOF	PASS	
SUTKUS	B13-0303	FOOTING	PASS	
ANDERSON	B13-0275	FOOTING	FAIL	*NEED OPEN HOLE SIGN OFF FROM ENGINEER.*
ZAPFEL	B13-0288	FOOTING		*OK ONLY AFTER THE PLAN CHANGE HAS BEEN APPROVED*