Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JULY 11, 2013**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
PETERS	B11-0252	FRAME	PASS	
MILYKI RANCH LLC	B13-0162	FOOTING	PASS	
YMCA OF THE ROCKIES	B13-0081	UNDERGROUND PLUMBING	PASS	
STUART	B12-0414	FRAME	FAIL	*TRUSSES ARE 50 PSF—SHOULD BE 70 PSF*
McMURDO	B12-0563	FINAL	PASS	