

**Grand County Building Department
Daily Inspection Record**

DATE OF INSPECTION: JULY 27, 2012

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
KING	B12-0310	PIER	PASS	
LOCKWOOD	B11-0054	STAIRS, HANDRAIL	FAIL	
MARTELLA	B12-0295	GAS	PASS	<i>PIPING PASSED NEED DRIP LEG BEFORE FEEDING APPLIANCE</i>
ZAK	B12-0297	GAS	PASS	
HABITAT FOR HUMANITY	B12-0241HSS	FOOTING	PASS	
EAGEN	B11-0409	SIDING	PASS	
GORDON LIVING TRUST	B12-0306	ICE AND WATER	PASS	
CARLSON	B12-0286	PIER	PASS	
KARR	B12-0037	INSULATION	PASS	
TT2, LLC	B10-0056	FINAL	PASS	
HAGERTY	B12-0268	FOUNDATION	PASS	
VOLKMER	B12-0285	FOUNDATION	PASS	
EAGLE RIDGE ON THE SUMMIT	B12-0276	ICE AND WATER	FAIL	
BISHOP	B12-0280	GAS	PASS	
WILLAIMS	B12-0307			