Grand County Building Department
Daily Inspection Record

DATE OF INSPECTION: **SEPTEMBER 24, 2012**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
HARRIS	B12-0420	ICE AND WATER	PASS	
FOSTER	B12-0436	FOUNDATION	PASS	
BRAUN	B12-0427	FINAL	PASS	
YODER	B12-0412	FINAL	PASS	
SIMEK	B12-0394	FOUNDATION	PASS	
KLUTSCH	B12-0452	FOOTING	FAIL	***BUILDING 26'6" FROM FRONT SETBACK***
PETTET	B12-0198	ROUGH PLUMBING	PASS	
PETTET	B12-0198	GAS	PASS	
DORIGAN	B12-0554	FINAL	FAIL	***NEED HAND RAIL***
GRAND AVIATION	B12-0374	FOUNDATION	PASS	
CROSS	B12-0225	INSULATION	PASS	
MIELKE	B12-0270	ICE AND WATER	PASS	
MIELKE	B12-0270	FRAME	FAIL	***HEADERS ARE WRONG SOME TRSS BRACING MISSING***
WEEMS	S12-0029	SEPTIC	FAIL	***NOT ENOUGH CHAMBERS***
OHMART	B12-0363	FOUNDATION	CANCEL	
APPLEQUIST	B12-0396	FINAL	PASS	